


## A Intumescent seal, with brush strip

- Generally for half hour fire and smoke doors
- Self adhesive fixing
- Certifire approved, certificate No. CF276
- Passed as BS 476 part 22 and 31.1
- LANTAC Building Control Approved
- NHBC Type Approved



White finish




Size 10 x 4 mm	1050 mm	2100 mm
White	950.18.157	950.18.107
Brown	950.18.151	950.18.101

Order qty: 1 pc

## B Intumescent seal, with brush strip

- Generally for half hour fire and smoke doors
- Self adhesive fixing
- Certifire approved, certificate No. CF276
- Passed at BS 476 part 22 and 31.1
- LANTAC Building Control Approved
- NHBC Type Approved



White finish




Size 15 x 4 mm	1050 mm	2100 mm
White	950.18.167	950.18.117
Brown	950.18.161	950.18.111

Order qty: 1 pc

## C Intumescent seal, with brush strip

- Generally for one hour fire and smoke doors
- Self adhesive fixing
- Passed at BS 476 part 22 and 31.1
- LANTAC Building Control Approved
- NHBC Type Approved



White finish




Size 20 x 4 mm	1050 mm	2100 mm
White	950.18.177	950.18.127
Brown	950.18.171	950.18.121

Order qty: 1 pc

## D Intumescent seal, with brush strip

- Generally for one hour fire and smoke doors
- Self adhesive fixing
- Passed at BS 476 part 22 and 31.1
- LANTAC Building Control Approved
- NHBC Type Approved



White finish




Size 25 x 4 mm	1050 mm	2100 mm
White	950.18.187	950.18.137
Brown	950.18.181	950.18.131

Order qty: 1 pc

## E Intumescent seal, with brush strip

- Generally for one hour fire and smoke doors
- Self adhesive fixing
- Passed at BS 476 part 22 and 31.1
- LANTAC Building Control Approved
- NHBC Type Approved



White finish



Size 30 x 4 mm	1050 mm	2100 mm
White	950.18.197	950.18.147
Brown	950.18.191	950.18.141

Order qty: 1 pc